

Certificate

No. c8278a-23

Customer:

eku Kabel & Systeme GmbH & Co. KG
Hansastraße 122 - 124
44866 Bochum, Germany

Class Ea

Test sample(s):

data cable:

Installation Cable ekuLan1000 Cat.7, S-FTP, AWG23, Dca/Cca/B2ca

Part no.: k64501011; k64501012; k64501041; k64501141; k64501042; k64501142;
k64501043; k64501044; k64501242; k64501611; k64501641; k64501642;
k64502011; k64502012; k64502041; k64502042; k64502043; k64506041;
k64511041; k64511241; k64511641; k64511042; k64512041; k64512241;
k64512042; k64531041; k64531641; k64532041; k64541041; k64541641;
k64541241; k64541441

connecting hardware:

eku E-Stone Modul Cat.6A, Keystone, shielded

Part no.: t66851000

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)

DIN EN 50173-1 (2018-10)

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

2 Connector Permanent Link, Copper, Class Ea

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **R8278a-23** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of testing.

Bexbach, 10.11.2023



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG

In der Kolling 320
66450 Bexbach / Germany

PO box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

Test laboratory accredited by DAKKS in accordance with DIN EN ISO/IEC 17025:2018.
The accreditation is valid for the test methods listed in certificate **D-PL-17559-01-00**.

**RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.**